ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT



No.: KA/17/05/15

Date : 18/5/2017

Name & Adress : A.E.E BAGALGUNTE
P/14, DASARALLI SUB DIVISION
Bangalore

Purpose of Ground Water : Domestic (Drinking)

Ground Water Potential : GOOD

Site Location : SIDDEDAhalli Sampangi Ramaheaha Layout

Topography : Plain Tessian

Soil : BROWNISH

Rock below the soil : Granitic-Schist (Metamorphic Rock)

Water Striking Levels					
	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	450-500 Ft.	750-880 Ft.	1060-1100 Ft.	190/210 Ft.	1500/1600 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

ರಕ್ಷಾಯುಕ್ತ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಟಿ. ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT

No.: KA/17/05/15

Date : 18/5/2017

Name & Adress : A.E.E BAGALGUNTE
W/14 Dasarahalli Sub Division
Bangalore

Purpose of Ground Water : Domestic (Drinking)

Ground Water Potential : Good

Site Location : Siddeshwara Layout

Topography : Plain Terrain

Soil : BROWNISH RED

Rock below the soil : Granitic Schist (Metamorphic Rock)

Water Striking Levels

	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	500-600 Ft.	850-900 Ft.	1000-1150 Ft.	190-210 Ft.	2100/2300 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

ಕರ್ನಾಟಕ ಸಾರ್ವಜನಿಕ ಆರೋಗ್ಯ ಅಭಿಯಂತರರು
ಟಿ. ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT



No.: KA/17/05/15

Date : 18/5/2017

Name & Adress : A.E.E. BAGALGUNTE

20/14, DASARALLI SUB DIVISION

Bangalore

Purpose of Ground Water : Domestic (Corridors)

Ground Water Potential : Good

Site Location : KIRLOSKAR LAYOUT

Topography : Plain Terrain

Soil : Brownish

Rock below the soil : Granitic Schist (Metamorphic Rock)

Water Striking Levels					
	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	550-650 Ft.	790-840 Ft.	950-1100 Ft.	170 Ft.	1800/1900 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ. ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT



No.: KA/17/05/15 Date : 18/5/2017

Name & Adress : A.E.E- BAGALGUNTE
D/14, Dasarahalli SUB DIVISION
Bangalore

Purpose of Ground Water : Domestic (Drinking)

Ground Water Potential : Good

Site Location : Royal Enclave D/14

Topography : Plain Terrain

Soil : Brownish

Rock below the soil : Granitic Schist (Metamorphic Rock)

Water Striking Levels

	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	600-700 Ft.	850-950 Ft.	1000-1150 Ft.	180-190 Ft.	1800/2400 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ. ದಾಸರಹಳ್ಳಿ ಉಪ ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ ಬೆಂಗಳೂರು

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT

No.: KA/17/05/15 Date : 18/5/2017

Name & Adress : A.EE BAGALGONTTE
D/14 Dasagalli Sub Division
Bangalore

Purpose of Ground Water : Domestic (Drinking)

Ground Water Potential : Very Good

Site Location : Soundarya layout ward No 14

Topography : Plain Terrian

Soil : Brownish RED

Rock below the soil : Granite Schist (Metamorphic Rock)

Water Striking Levels YIELD REPORT

	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	500-600 Ft.	700-800 Ft.	850-1050 Ft.	150-180 Ft.	1800/1900 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ. ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

(ARISH BABU R.R.)
Consultant Geologist / Diviner